

# **SOYAL**

## **701 Server MODBUS IO Mapping**

Version 1.02

Date January 7, 2022

**Home Series (AR721H & 727HV3)**Controller IO& Modbus IO Corresponding Mapping Table: **DO**

DO-0			
Pp	Controller Functions	Status	Value
00	Door Relay	On/Off	1/0
01	Alarm Relay	On/Off	1/0
02			1/0
03			1/0
04			1/0
05			1/0
06			1/0
07			
08			
09			
10			
11			
12			
13			
14			
15			

**Home Series (AR721H & 727HV3)**Controller IO& Modbus IO Corresponding Mapping Table: **DI**

DI-0			
Pp	Controller Functions	Status	Value
00	Door Sensor	Open/Close	1/0
01	Arm Status	ARMING/Disarm	1/0
02	Egress	Close/Open	1/0
03	Alarm Status (Force or Open too long)	On/Off	
04	Door Open too Long	On/Off	
05	Force Open Alarm (Illegally Open Door)	On/Off	
06	Duress Alarm	On/Off	
07			
08			
09			
10			
11			
12			
13			
14			
15	Online	Under Multi Door Control Panel	

		AR-716E16 RS485 Connection Status	
--	--	-----------------------------------	--

511	Fire State		1/0
-----	------------	--	-----

**Enterprise Series & AR-716-E16(AR-721Ev2)**Controller IO Modbus IO Corresponding Mapping Table: **DO**

Main	WG							Function	Status	Value
256	272							Door Relay	On/Off	1/0
257	273							Alarm Relay	On/Off	1/0
258	274									1/0
259	275									1/0
260	276									1/0
261	277									1/0
262	278									1/0
263	279								On/Off	1/0
264	280									
265	281									
266	282									
267	283									
268	284									
269	285									
270	286									
271	287									

**Enterprise Series & AR-716-E16(AR-721Ev2)**Controller IO Modbus IO Corresponding Mapping Table: **DI**

Main	WG							Function	Status	Value
256	272							Door Sensor	On/Off	1/0
257	273							Arm Status	On/Off	1/0
258	274							Egress		1/0
259	275							Alarm Status (Force /Open too long)		1/0
260	276							Door Open too Long		1/0
261	277							Force Open Alarm		1/0
262	278							Duress Alarm		1/0
263	279								On/Off	1/0
264	280									
265	281									
266	282									
267	283									
268	284									
269	285									
270	286									
271	287							On Line / Off Line	On/Off	1/0

511		Fire Alarm State		1/0
-----	--	------------------	--	-----

<b>Controller Wired under AR-716-E16(AR-721Ev2)</b>										
Controller IO & Modbus IO Corresponding Mapping Table: <b>DO</b>										
Controller Node ID										
<b>01</b>	<b>02</b>	<b>03</b>	<b>04</b>	<b>05</b>	<b>06</b>	<b>07</b>	<b>08</b>	Function	Status	Value
0	16	32	48	64	80	96	112	Door Relay	On/Off	1/0
1	17	33	49	65	81	97	113	Alarm Relay	On/Off	1/0
2	18	34	50	66	80	98	114			1/0
3	19	35	51	67	83	99	115			1/0
4	20	36	52	68	84	100	116			1/0
5	21	37	53	69	85	101	117			1/0
6	22	38	54	70	86	102	118			1/0
7	23	39	55	71	87	103	119			1/0
8	24	40	56	72	88	104	120			
9	25	41	57	73	89	105	121			
10	26	42	58	74	90	106	122			
11	27	43	59	75	91	107	123			
12	28	44	60	76	92	108	124			
13	29	45	61	77	93	109	125			
14	30	46	62	78	94	110	126			
15	31	47	63	79	95	111	127			

<b>Controller Wired under AR-716-E16(AR-721Ev2)</b>										
Controller IO & Modbus IO Corresponding Mapping Table: <b>DO</b>										
Controller Node ID										
<b>09</b>	<b>10</b>	<b>11</b>	<b>12</b>	<b>13</b>	<b>14</b>	<b>15</b>	<b>16</b>	Function	Status	Value
128	144	160	176	192	208	224	240	Door Relay	On/Off	1/0
129	145	161	177	193	209	225	241	Alarm Relay	On/Off	1/0
130	146	162	178	194	210	226	242			1/0
131	147	163	179	195	211	227	243			1/0
132	148	164	180	196	212	228	244			1/0
133	149	165	181	197	213	229	245			1/0
134	150	166	182	198	214	230	246			1/0
135	151	167	183	199	215	231	247			1/0
136	152	168	184	200	216	232	248			
137	153	169	185	201	217	233	249			
138	154	170	186	202	218	234	250			
139	155	171	187	203	219	235	251			
140	156	172	188	204	22	236	252			

141	157	173	189	205	221	237	253			
142	158	174	190	206	222	238	254			
143	159	175	191	207	223	239	255			

<b>Controller Wired under AR-716-E16(AR-721Ev2)</b>										
Controller IO & Modbus IO Corresponding Mapping Table: <b>DI</b>										
Controller Node ID										
<b>01</b>	<b>02</b>	<b>03</b>	<b>04</b>	<b>05</b>	<b>06</b>	<b>07</b>	<b>08</b>	Function	Status	Value
0	16	32	48	64	80	96	112	Door Sensor	Open/Close	1/0
1	17	33	49	65	81	97	113	Arm Status	Arm/Disarm	1/0
2	18	34	50	66	80	98	114	Egress	Close/Open	1/0
3	19	35	51	67	83	99	115	Alarm On (Force or Open too long)	On/Off	1/0
4	20	36	52	68	84	100	116	Door Open too Long	On/Off	1/0
5	21	37	53	69	85	101	117	Force Open Alarm	On/Off	1/0
6	22	38	54	70	86	102	118	Duress Alarm	On/Off	1/0
7	23	39	55	71	87	103	119			1/0
8	24	40	56	72	88	104	120			
9	25	41	57	73	89	105	121			
10	26	42	58	74	90	106	122			
11	27	43	59	75	91	107	123			
12	28	44	60	76	92	108	124			
13	29	45	61	77	93	109	125			
14	30	46	62	78	94	110	126			
15	31	47	63	79	95	111	127	RS485 Reader On Line / Off Line	On/Off	1/0

<b>Controller Wired under AR-716-E16(AR-721Ev2)</b>										
Controller IO & Modbus IO Corresponding Mapping Table: <b>DI</b>										
Controller Node ID										
<b>09</b>	<b>10</b>	<b>11</b>	<b>12</b>	<b>13</b>	<b>14</b>	<b>15</b>	<b>16</b>	Function	Status	Value
128	144	160	176	192	208	224	240	Door Sensor	Open/Close	1/0
129	145	161	177	193	209	225	241	Arm Status	Arm/Disarm	1/0
130	146	162	178	194	210	226	242	Egress	Close/Open	1/0
131	147	163	179	195	211	227	243	Alarm On (Force or Open too long)	On/Off	1/0
132	148	164	180	196	212	228	244	Door Open too Long	On/Off	1/0
133	149	165	181	197	213	229	245	Force Open Alarm	On/Off	1/0
134	150	166	182	198	214	230	246	Duress Alarm	On/Off	1/0
135	151	167	183	199	215	231	247			1/0
136	152	168	184	200	216	232	248			
137	153	169	185	201	217	233	249			

138	154	170	186	202	218	234	250			
139	155	171	187	203	219	235	251			
140	156	172	188	204	22	236	252			
141	157	173	189	205	221	237	253			
142	158	174	190	206	222	238	254			
143	159	175	191	207	223	239	255	RS485 Reader On Line / Off Line	On/Off	1/0

511							Fire State	On/Off	1/0
-----	--	--	--	--	--	--	------------	--------	-----

**AR-727CM-IO (TCP Port 1601) IO & Modbus IO Mapping Table**

DO-0			
Pp	Controller IO	Status	Value
00	DO-0	On/Off	1/0
01	DO-1	On/Off	1/0
02	DO-2	On/Off	1/0
03	DO-3	On/Off	1/0
04	DO-4	On/Off	1/0
05	DO-5	On/Off	1/0
06	DO-6	On/Off	1/0
07	DO-7	On/Off	1/0
08			
09			
10			
11			
12			
13			
14			
15			

DI-0			
Pp	Controller IO	Status	Value
00	DI-0	Open/Close	1/0
01	DI-1	Open/Close	1/0
02	DI-2	Open/Close	1/0
03	DI-3	Open/Close	1/0
04	DI-4	Open/Close	1/0
05	DI-5	Open/Close	1/0
06	DI-6	Open/Close	1/0
07	DI-7	Open/Close	1/0
08			
09			
10			
11			
12			
13			
14			
15	Online	RS485 Reader On Line / Off Line	

511	Fire State		1/0
-----	------------	--	-----



**AR403MO (RS-485) IO & Modbus IO Mapping Table**

DO-0			
Pp	Controller IO	Status	Value
00	DO-0	On/Off	1/0
01	DO-1	On/Off	1/0
02	DO-2	On/Off	1/0
03	DO-3	On/Off	1/0
04			
05			
06			
07			
08			
09			
10			
11			
12			
13			
14			
15			

DI-0			
Pp	Controller IO	Status	Value
00	DI-0	Open/Close	1/0
01	DI-1	Open/Close	1/0
02	DI-2	Open/Close	1/0
03	DI-3	Open/Close	1/0
04			
05			
06			
07			
08			
09			
10			
11			
12			
13			
14			
15	Online	RS485 Connection Status	

### 701ServerSQL Modbus Bridge Area Address Assignment (IO Address assignment)

701ServerSQL is built-in Modbus TCP to Modbus RTU bridge function. It can support 16 areas, 254 controllers per area and 4906 points per controller. Due to the Modbus IO Address does not have a partition field of Area, 701ServerSQL area code must be brought into the Modbus IO Address to fully utilize the area IO points with more than 10 million points.

The Formula is : Area Modbus IO Address = (Area Code) \* 4096 + (Controller IO Address).

For example: The IO is in (Area):3 , Controller Node ID :2 , IO Number:251 add Area number will become IO Address:12539 ◦

Modbus IO	Number Range	
Area	0 ~ 15	
Node ID	1 ~ 254	
IO Address	0 ~ 4096	16 Bits

### IO Address Bit Mapping

IO Address	16 Bits Modbus Address	
Modbus Format	Bit 15~12	Bits 11 ~00
701ServerSQL Format	Area Code	Modbus IO Address